



Long Island Oilheat-Realty Partnership Program



 Storage Tanks Used NASSAU COUNTY 1100 Gals. or Less More than 1100 Gals.		 for On-Site Heating SUFFOLK COUNTY 1100 Gals. or Less More than 1100 Gals.			
Registration Required	No	Yes	Registration Required	No	Yes
Testing Required	No	Yes	Testing Required	No	Yes
Test Schedule	NONE	Annually for corrodible tanks installed before 8/1/66; every 2 years if installed after 8/1/66. Every 5 years for non-corrodible tanks	Test Schedule	NONE	On 10th anniversary, and every 5 years thereafter
New Tank Standards			New Tank Standards		
Underground	Single-Walled non-corrodible	Double-Walled or equivalent	Underground	Single-Walled non-corrodible	Double-Walled or equivalent
Aboveground	275-gal. on concrete pad at a single family residence only otherwise, same	Dike; impervious underlayment; monitoring; overfill protection	Aboveground	YES	Dike; impervious underlayment; monitoring; overfill protection
Abandonment Allowed	Yes, with affidavit that tank is not leaking	Yes, with tightness test within past 90 days, or monitoring well for one year	Abandonment Allowed	YES	Yes, with waiver from County
Removal or Abandonment Deadline	NONE	All tanks installed prior to 8/1/86 have now been replaced	Removal or Abandonment Deadline	NONE	None for tank used for on-premises space heating

